

Item #	Building	Floor Tiles (& mastic)	Above Ceiling Fire Proofing	Mudded Pipe Fittings	Ceiling Tiles	Pipe Insulation
9	28. Cleveland - Constructed 1966					
10	Basement	Yes	No	PACM	No	PACM
11	First Floor	Yes	No	PACM	No	PACM
12	Second Floor	Yes	No	PACM	No	PACM
13	Third Floor	Yes	No	PACM	No	PACM

<b>Mechanical Rooms</b>	<b>Gasket Material</b>	<b>Window Caulking</b>	<b>Transite</b>	<b>Dry Wall Compound</b>	<b>Crawl Space</b>	<b>Fire Doors</b>
Abated	PACM	PACM	PACM	PACM	N/A	Yes
N/A	PACM	N/A	PACM	N/A	N/A	Yes
N/A	PACM	N/A	PACM	PACM	N/A	Yes
N/A	PACM	N/A	PACM	PACM	N/A	Yes